



UPVC PIPE - PNS 65  
Scale NTS

## MATERIAL

UPVC MATERIAL IS IN ACCORDANCE TO PNS 65:1993

RING GASKET: MACHINE-INSTALLED METAL REINFORCED  
INTEGRATED GASKET SEAL

## JOINTS

UPVC PIPES SHALL BE PUSH-ON TYPE JOINT WITH  
RUBBER RING GASKET

## MARKINGS (ENGRAVE)

1. NAME OF THE MANUFACTURER
2. NAME OF PRODUCT
3. NOMINAL OUTSIDE DIAMETER
4. SERIES OR NOMINAL PRESSURE RATING (MPA)
5. THE WORDS "FOR POTABLE WATER"
6. THE WORDS "MADE IN PHIL."
7. QUALITY MARK LOGO
8. DATE MANUFACTURED

NOMINAL SIZE mm	NOMINAL OUTSIDE DIAMETER (OD) mm	DIAMETER TOLERANCE mm	MINIMUM SOCKET DEPTH mm	EFFECTIVE LENGTH (L) mm	WALL THICKNESS SERIES 8 (C - 150)	
					MIN.	MAX.
200	225	225.70	154	6000	12.90	14.39



Province of Bukidnon  
Municipality of Marikina City  
Marikina City District

Project :

8" Ø UPVC PIPE SPECIFICATIONS

Prepared by:

JOAN N. CANETE

Checked by:

Engr. ERMITO L. GANAS  
Engineering and Maintenance Head

Approved by:

Engr. ROGELIO K. PANGAN  
General Manager

Sh#

1/1