



MANOLO FORTICH WATER DISTRICT

A. Ditona St., Tankulan, Manolo Fortich, Bukidnon

Contact No.: 0917-718-1311

Email: mfwd_buk@yahoo.com

BIDS AND AWARDS COMMITTEE

SUPPLEMENTAL BID BULLETING NUMBER 2

INVITATION TO BID FOR THE PROCUREMENT OF VARIOUS UPVC PIPES FOR MANOLO FORTICH WATER SUPPLY IMPROVEMENT PROJECT OF MANOLO FORTICH WATER DISTRICT

Invitation for Bids No.: WDDSP-MFWD-IFB-G11b

Approved Budget for the Contract (ABC) is **PhP87,747,673.16**

This Supplemental/Bid Bulletin No. 2 is being issued to add, modify and amend provisions in the Bidding Documents.

From				To																																			
Section VIII Technical Specifications																																							
I. UNPLASTICIZED POLYVINYL CHLORIDE (uPVC)																																							
A. Various uPVC Pipes																																							
Pipe shall conform to the requirements on the standards for Unplasticized Polyvinyl Chloride (uPVC) “Pressure Pipes” and shall comply with ISO 1452 (Series 8) and PNS 65:1993 (Series 10). The supply of pipe included in the approved Program of Work are pipelaying of approximately 23,500 linear meters of sizes ranging from 250mmø to 350mmø pipes, and shall have the following features and specifications:				Pipe shall conform to the requirements on the standards for Unplasticized Polyvinyl Chloride (uPVC) “Pressure Pipes” and shall comply with PNS 65:1993 (Series 8) . The supply of pipe included in the approved Program of Work are pipelaying of approximately 23,500 linear meters of sizes ranging from 250mmø to 350mmø pipes, and shall have the following features and specifications:																																			
A.1 Dimension																																							
<table><tr><th>Nominal Pipe Size Inside Diameter (mm)</th><th>Nominal Outside Diameter (mm)</th><th>Quantity (Pieces)</th><th>Wall Thickness Series 8 minimum (mm) ISO 1452</th></tr><tr><td>350</td><td>355</td><td>525</td><td>20.3</td></tr><tr><td>300</td><td>315</td><td>3,050</td><td>18.0</td></tr><tr><td>250</td><td>280</td><td>342</td><td>16.0</td></tr></table>				Nominal Pipe Size Inside Diameter (mm)	Nominal Outside Diameter (mm)	Quantity (Pieces)	Wall Thickness Series 8 minimum (mm) ISO 1452	350	355	525	20.3	300	315	3,050	18.0	250	280	342	16.0	<table><tr><th>Nominal Pipe Size (mm)</th><th>Nominal Outside Diameter (mm)</th><th>Quantity (Pieces/lm)</th><th>Wall Thickness Series 8 minimum (mm)</th></tr><tr><td>350</td><td>355</td><td>525/3,150</td><td>20.3</td></tr><tr><td>300</td><td>315</td><td>3,050/18,300</td><td>18.0</td></tr><tr><td>250</td><td>280</td><td>342/2,052</td><td>16.0</td></tr></table>				Nominal Pipe Size (mm)	Nominal Outside Diameter (mm)	Quantity (Pieces/lm)	Wall Thickness Series 8 minimum (mm)	350	355	525/3,150	20.3	300	315	3,050/18,300	18.0	250	280	342/2,052	16.0
Nominal Pipe Size Inside Diameter (mm)	Nominal Outside Diameter (mm)	Quantity (Pieces)	Wall Thickness Series 8 minimum (mm) ISO 1452																																				
350	355	525	20.3																																				
300	315	3,050	18.0																																				
250	280	342	16.0																																				
Nominal Pipe Size (mm)	Nominal Outside Diameter (mm)	Quantity (Pieces/lm)	Wall Thickness Series 8 minimum (mm)																																				
350	355	525/3,150	20.3																																				
300	315	3,050/18,300	18.0																																				
250	280	342/2,052	16.0																																				

A.6 ISO Rating		A.6 PNS Rating													
In accordance to 1452 for uPVC pipe		In accordance to PNS 65:1993													
B. Other Requirements															
xxx...	B.3. Composition of seal kit shall be free from any metal with certification issued by DTI (National level) and notarized.	xxx...	B.3. Composition of machine installed fixed seal kit shall be manufactured outside the Philippines and be free from any metal with certification issued by the manufacturer												
xxx...		xxx...													
Statement of Compliance															
<table><tr><td>A</td><td>350 mm diameter – Series 8</td></tr><tr><td>a</td><td>Pipe Composition</td></tr><tr><td></td><td>- in accordance to ISO Rating 1452</td></tr></table>		A	350 mm diameter – Series 8	a	Pipe Composition		- in accordance to ISO Rating 1452	<table><tr><td>A</td><td>350 mm diameter – Series 8</td></tr><tr><td>a</td><td>Pipe Composition</td></tr><tr><td></td><td>- in accordance to PNS 65:1993</td></tr></table>		A	350 mm diameter – Series 8	a	Pipe Composition		- in accordance to PNS 65:1993
A	350 mm diameter – Series 8														
a	Pipe Composition														
	- in accordance to ISO Rating 1452														
A	350 mm diameter – Series 8														
a	Pipe Composition														
	- in accordance to PNS 65:1993														
<table><tr><td>B</td><td>300 mm in diameter – Series 8</td></tr><tr><td>a</td><td>Pipe Composition</td></tr><tr><td></td><td>- in accordance to ISO Rating 1452</td></tr></table>		B	300 mm in diameter – Series 8	a	Pipe Composition		- in accordance to ISO Rating 1452	<table><tr><td>B</td><td>300 mm in diameter – Series 8</td></tr><tr><td>a</td><td>Pipe Composition</td></tr><tr><td></td><td>- in accordance to PNS 65:1993</td></tr></table>		B	300 mm in diameter – Series 8	a	Pipe Composition		- in accordance to PNS 65:1993
B	300 mm in diameter – Series 8														
a	Pipe Composition														
	- in accordance to ISO Rating 1452														
B	300 mm in diameter – Series 8														
a	Pipe Composition														
	- in accordance to PNS 65:1993														
<table><tr><td>C</td><td>250 mm in diameter – Series 8</td></tr><tr><td>a</td><td>Pipe Composition</td></tr><tr><td></td><td>- in accordance to ISO Rating 1452</td></tr></table>		C	250 mm in diameter – Series 8	a	Pipe Composition		- in accordance to ISO Rating 1452	<table><tr><td>C</td><td>250 mm in diameter – Series 8</td></tr><tr><td>a</td><td>Pipe Composition</td></tr><tr><td></td><td>- in accordance to PNS 65:1993</td></tr></table>		C	250 mm in diameter – Series 8	a	Pipe Composition		- in accordance to PNS 65:1993
C	250 mm in diameter – Series 8														
a	Pipe Composition														
	- in accordance to ISO Rating 1452														
C	250 mm in diameter – Series 8														
a	Pipe Composition														
	- in accordance to PNS 65:1993														
Section VIII Bidding Forms															
For Goods Offered From Abroad															

1	2	3	4
Item	Description	Country of origin	Quantity
a	350mmØ		525 pcs
b	300mmØ		3,050 pcs
c	250mmØ		342 pcs

1	2	3	4
Item	Description	Country of origin	Quantity
a	350mmØ		525 pcs / 3,150 lm
b	300mmØ		3,050 pcs / 18,300 lm
c	250mmØ		342 pcs / 2,052 lm

For Goods Offered From Within the Philippines

1	2	3	4
Item	Description	Country of origin	Quantity
a	350mmØ		525 pcs
b	300mmØ		3,050 pcs
c	250mmØ		342 pcs

1	2	3	4
Item	Description	Country of origin	Quantity
a	350mmØ		525 pcs / 3,150 lm
b	300mmØ		3,050 pcs / 18,300 lm
c	250mmØ		342 pcs / 2,052 lm

This Supplemental Bid Bulletin No. 2 shall form part of the Bidding Documents. Any provisions in the Bidding Documents inconsistent herewith is hereby amended, modified and superseded accordingly.

For the guidance and information of all concerned.

Issued this 3rd day of June 2020 at Manolo Fortich Water District, Manolo Fortich, Bukidnon.

Reviewed and approved by:


ROSE VILMA JOY T. VEGA
Vice Chairman


ENGR. ERMITO L. GANAS
BAC Chairman


EVELYN C. NARA
Member


ALDWIN L. OLAIVAR
Member


FEDERICO J. AGBAY
Member