



MANOLO FORTICH WATER DISTRICT
A. Ditona St., Tankulan, Manolo Fortich, Bukidnon
Contact No.: 0917-718-1311
Email: mfwd_buk@yahoo.com

BIDS AND AWARDS COMMITTEE

SUPPLEMENTAL BID BULLETING NUMBER 1

**INVITATION TO BID FOR SUPPLY AND DELIVERY OF 500
LENGTHS 6" DIAMETER UPVC PIPES SERIES 8**

ITB Number: 21-01-001

Approved Budget for the Contract (ABC) is **P 3,746,400.00**

This Supplemental/Bid Bulletin No. 1 is being issued to add, modify and amend provisions in the Bidding Documents.

A. Section VII. Technical Specification

From	To
A.1 Dimension Wall Thickness Series 8 Minimum (MM) PNS 65:1993 6.3	A.1 Dimension Wall Thickness Series 8 Minimum (MM) PNS 65:1993 9.2
A.3 Machine Installed Fixed Seal The composition of built-in metal/rubber seal is the flexible EPDM rubber element to effectively seal against spigot and socket conforming to PNS 1008. 1. Contamination –free 2. Leak – free 3. Ensuring clean, safe drinking water	A.3 Machine Installed Fixed Seal The composition of two-component built-in seal, the flexible EPDM rubber element to effectively seal against spigot and socket, and a reinforcing carbon steel element bonded to the rubber element to hold the seal in the correct position and firm in place, that can resist pressure effectively under both positive and negative following the best practice of sealing using European Belling Equipment. EPDM Rubber Seal Materials in accordance to ISO 4633 and Carbon Steel complying SAE1008. 1. Contamination –free 2. Leak – free

	3. Ensuring clean, safe drinking water
Statement of Compliance: A.a. Pipe Composition (Line 10 & 11) <ul style="list-style-type: none"> - 15° chamfered at tail end in accordance to ISO 1452-2 - Socket type in accordance to ISO 1452-2 	Statement of Compliance: A.a. Pipe Composition (Line 10 & 11) <ul style="list-style-type: none"> - 15° chamfered at tail end in accordance to PNS 65:1993 - Socket type in accordance to PNS 65:1993
B. Jointing / Seal <ul style="list-style-type: none"> - Machine-installed metal reinforced integrated gasket seal in accordance to ISO 9001:2015 & 14001:2015 	B. Jointing / Seal <ul style="list-style-type: none"> - Machine-installed metal reinforced integrated gasket seal in accordance to ISO 4633 (EPDM rubber) and SAE1008 (Carbon Steel)

B. Additional Requirements:


B.7 Certificate notarized and issued by the installer that the machine-installed metal reinforced integrated gasket seal are installed following the best practice of sealing using the European Belling Equipment.

This Supplemental Bid Bulletin No. 1 shall form part of the Bidding Documents. Any provisions in the Bidding Documents inconsistent herewith is hereby amended, modified and superseded accordingly.


For the guidance and information of all concerned.

Issued this 14th day of January 2021 at Manolo Fortich Water District, Manolo Fortich, Bukidnon.

Reviewed and approved by:



ENGR. ERMITO L. GANAS
BAC Chairman



ROSE VILMA JOY T. VEGA
Vice Chairman



ALDWIN L. OLAIVAR
Member



EVELYN C. NARA
Member



FEDERICO J. AGBAY
Member